For more assistance with technical questions please call our technical support staff at (714) 259-9959. You can also contact us by email at info@brucklightingsystems.com.

# BRUCK


# INSTALLATION INSTRUCTIONS

#### V/A

#### V/A 300W DIRECT FEED TRANSFORMER

Art. No.

240325bzbronze240325chchrome240325mcmatte



#### Â

### IMPORTANT SAFETY INSTRUCTIONS

- 1. THIS PRODUCT MUST BE INSTALLED BY A PERSON FAMILIAR WITH THE CONSTRUCTION AND OPERATION OF THE PRODUCT AND THE HAZARDS INVOLVED, IN ACCORDANCE WITH LOCAL NEC CODE.
- 2. FOR USE WITH V/A NETWORK ONLY.
- The V/A track system is not intended for use with a power supply cord or convenience receptacle adaptor. This track system is to be supplied by Bruck Lighting.
- Do not install this rail in damp or wet locations.
- 5. Do not install any part of a rail system less than 5 feet above the floor.
- 6. Do not install any fixture assembly closer than 6 inches from any curtain, or similar combustible material.
- 7. Disconnect electrical power before adding to or changing the configuration of the track.
- Do not attempt to energize anything other than lighting rail fixtures on the rail. To reduce the risk of fire and electric shock, do not attempt to connect power tools, extension cords, appliances, and the like to the rail.
- 9. This track system MUST BE HARD WIRED. For all the wire connections, use Listed Wire Nuts.
- 10. Secondary connections must be clean and tight to avoid arcing and overheating!
- 11. Warranty is void in case of unauthorized modifications and/ or improper use.


## READ ALL OF THESE INSTALLATION INSTRUCTIONS BEFORE INSTALLING THE SYSTEM

#### This Package Contains: V/A 300W Direct Feed Transformer - qty.(1)

- Connect the wires (A) from the canopy to the power supply cables from the transformer. Insert the screws (C) into the mounting plate (B) and tighten.

- Place the cover (D) over the mounting plate (B) and secure it with the allen screw (E) located on the side of the base.

- Slide the V/A track into power feed (F) and tighten set screws (G).



USA

Â