Single Feed

800RLP4C02S

1.9





GENERAL PRODUCT INFORMATION:



This product is suitable for indoor dry locations only.

This product must be used with Tiella lighting system only.

Install the Power Feed Canopy

NOTE: Use the provided universal round crossbar when the canopy holes do not line up with the electrical box holes.

NOTE: The low voltage wires from the remote transformer must be present in electrical box. Follow the instruction provided with the remote transformer prior to these steps.



1 Connect the low voltage wires to the power feed canopy wires with the wire nuts.

CAUTION—RISK OF FIRE

This product requires installation by a qualified electrician. Before installing be sure to read all instructions and TURN THE POWER TO THE ELECTRICAL BOX OFF.



2 Place all wire nut connections properly into the electrical box.

3 Mount the power feed canopy to the electrical box with two #8-32 flat head Phillips screws.



4 Remove the cap from the housing.

5 DO NOT REMOVE the insulator unless the power feed connector is going to be mounted onto the conductive rail join connector.

Mount the Rail Directly to the Power Feed Canopy



Push the rail into the housing so that the rail fits in the middle of insulator.



2 Replace and tighten the cap to the housing.

NOTE: In case of cross threading, unscrew the cap from the housing and repeat step 2.

3 Tighten the screw on bottom of the cap with the 3/16 Allen wrench.

SPECIAL INSTALLATION: Mount the Conductive Rail Join Connector to the Power Feed Canopy



SAVE THESE INSTRUCTIONS!



7400 Linder Ave, Skokie, IL 60077 847.410.4400

www.tiella.com

© 2008 Tech Lighting, L.L.C. All rights reserved. The "tiella" graphic is a registered trademark of tiella. tiella reserves the right to change specifications for product improvements without notification. A Generation Brands Company