


# **MODELS** 770, 784 **VENTILATION FANS**



# Quiet ventilator built with high performance blower and attractive grille.

## **FEATURES**

## **GRILLE:**

- · Engineered resin construction
- · Low-profile blends well with any decor
- · Torsion spring grille mounting no tools required

- · Plug-in, permanently lubricated motor
- Designed for continuous operation

### HOUSING:

- · Rugged, 26-gage galvanized steel construction
- · Integral key-holed mounting brackets for easy, secure installation directly to joist
- Provision for wire suspension when installed in a drop
- 4-inch round, tapered, polymeric duct fitting with built-in backdraft damper for easy, positive duct connection and no metallic clatter

U.L. Listed for use over bathubs and showers when connected to a GFCI protected branch circuit

ENERGY STAR® qualified

# **SPECIFICATIONS**

MODEL	VOLTS	AMPS	
770	120	0.2	
784	120	0.3	

MODEL	STATIC PRESSURE	CFM	SONES	FAN WATTS	DUCT
770	0.10	50	1.5	17.5	4" Round
770	0.25	35			4 Houriu
784	0.10	80	2.0	26.1	4" Dound
/84	0.25	65			4" Round



HVI-2100 CERTIFIED RATINGS comply with new testing technologies and procedures prescribed by the Home Ventilating Institute, for off-the-shelf products, as they are available to consumers. Product performance is rated at 0.1 in. static pressure, based on tests conducted in a state-of-the-art test laboratory. Sones are a measure of humanly-perceived loudness, based on laboratory measurements.

Broan-NuTone LLC Hartford, Wisconsin www.broan.com 800-558-1711 Broan-NuTone LLC Mississauga, Ontario www.broan.ca 877-896-1119

REFERENCE	QTY.	REMARKS	Project		
			Location		
			Architect		
			Engineer		
			Contractor		
			Submitted by Date		

# **TYPICAL SPECIFICATION**

Fan shall be Broan Model 770 (784).

Unit shall have galvanized steel housing with integral mounting brackets. Unit shall have built-in backdraft damper and shall be ducted to a roof or wall cap.

Motor to be permanently lubricated and designed for continuous operation.

Air delivery shall be no less than 50 (80) cfm and sound level no greater than 1.5 (2.0) Sones. All air and sound ratings shall be certified by HVI.

Unit shall be U.L. Listed for use over bathtubs and showers when connected to GFCI protected branch circuit.

Unit shall be ENERGY STAR® qualified.

